

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1591:200 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

**DESIGN:** Models BPS10, BPS10C, BPS10220, BPS6220, BPS6 and BPS6C booster power supplies. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** BPS6, BPS6C, BPS10, BPS10C: 120 VAC  
BPS6220, BPS10220: 220 VAC

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All installations must be in accordance with NFPA 72, 1999 Edition.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as booster power supply for use with listee's separately listed compatible fire alarm control units to extend the notification appliances circuit.

**NOTE:** Formerly 7300-1388:225

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager